

SOUTH DELHI MUNICIPAL CORPORATION

Office of the Executive Engineer(E)
Central Zone, Zonal Office Building
Lajpat Nagar-II, New Delhi- 110024



No D-164 | EEE | ON 2/2013-14

Dated: 21.1.14

Sub: Corrigendum to NIT No-29, Item No-1 dt 2.12.13 (Tender No- 210820)

With reference to the above mentioned NIT, following amendments are hereby issued:

Amendment No 1:

The minutes of the pre-bid conference held in the office of SE(Elect)-I, SDMC on 23.12.13 at 11 AM as approved by Competent Authority are as follows:

S No	NIT No	Query/clarification	Firm which raised the query	Reply of the dept
1	29/1	For 20 passenger MRL lift with as per lift well size of 2550 mm W x 2450 mm D we will be able to provide the following: a) Car size: 1550mm W x 2000 mm D. However, in the tender it is mentioned as vice versa. b) Clear opening: 1000 mm W x 2000 mm H (Under heading "Detailed Technical parameters for the lifts to be supplied" Column 5 Serial No 6 & 8)	M/s Johnson Lift (P) Limited	Proposed car size is acceptable if the area of car is as per applicable IS/CPWD specifications. Proposed clear opening is acceptable to the dept if it is as per IS/ CPWD specifications.
2	29/1	We request you to provide Trap Door and Load Hook in the machine room for lift nos 1,2,3 & 6 and Load Hook in the lift shaft for lift no 4 & 5 as per approved drawings. Since, nothing is mentioned in the tender document. It will help in lifting the machine and for service purposes later on. This is required as per Indian	M/s Johnson Lift (P) Limited	As per NIT clause 5.0 of specifications part, Indian Standards related to the work are applicable. Hence, this is acceptable to the dept as per approved drawings.

		Standards also.		
3	29/1	We request you to clarify the size of doors for all the lifts (i.e. Clear opening). Otherwise , we will provide as per Indian Standards	M/s Johnson Lift (P) Limited	As per NIT clause 5.0 of specifications part, Indian Standards related to the work are applicable. Hence, this is acceptable to the dept.
4	29/1	We request you to clarify the type of flooring in the lift car for all the lifts. Since, nothing is mentioned in the tender document. Otherwise, we will provide PVC flooring.	M/s Johnson Lift (P) Limited	As per CPWD general specifications for electrical works (Part-III- Lifts & Escalators), 2003 chapter-IV section 6.11, the floor shall be with 3 mm thick PVC tiles for passenger lifts and chequered aluminium sheet for goods lift. The same is acceptable to the dept.

The above mentioned minutes shall form part of the NIT and are to be read by the intending tenderers with the existing conditions of the NIT.

Amendment No-2:

The tender schedule for sale and submission of tenders has been revised as follows:


S No	Stage	Start date & time	Expiry date & time
1	Purchase and download tender document	2.12.13 20:31 hrs	30.1.14 16:00 hrs
2	Online bid preparation & hash submission	2.12.13 20:31 hrs	10.2.14 15:00 hrs
3	Technical and financial lock	11.2.14 15:01 hrs	11.2.14 18:00 hrs
4	Re-encryption of online bids/ manual submission	11.2.14 18:01 hrs	13.2.14 15:00 hrs
5	Opening of technical bid	13.2.14 15:01 hrs	13.2.14 17:30 hrs
6	Evaluation of	13.2.14	19.2.14

	technical bid	17:31 hrs	14:00 hrs
7	Opening of financial bid	19.2.14 14:01 hrs	19.2.14 17:00 hrs
8	Evaluation of financial bid	19.2.14 17:01 hrs	25.2.14 15:00 hrs
9	Award of contract	25.2.14 15:00 hrs	4.3.14 15:00 hrs

Rest of the conditions of the tender shall remain same.

All concerned

AO (I.T) / SDMC - for upload on website
www.mcdonline.gov.in &
www.mcdetenders.com


 21/1/13
 EEE, Central Zone
 EXECUTIVE ENGINEER (ELECT.)
 CENTRAL ZONE, SDMC
 Ref 21/1