



NORTH DELHI MUNICIPAL CORPORATION
(ENGINEERING DEPARTMENT)

Office of Ex. Engineer (Elect.)-II, Civil Line Zone
M.C. Primary School, Hakikat Nagar, Delhi-09

No. E E (E)-II/NDMC/17-18/ 388

Date: 24/08/2017

Sub:- Clarifications regarding pre-bid meeting for the work of "Const. of 200 Bedded Hospital at Balak Ram Hospital at Timarpur in C-10/CLZ S.Head:- Providing addressable Fire Alarm System and Public Address System"

NIT No. EEE-II/TC/2017-18/12 Item No. 3 vide online tender No. 288211 dated 26.07.2017

A Pre-bid meeting was held under the Chairmanship of Chief Engineer (Elect)/North DMC on dt. 21-08-2017 at 03:00 PM regarding subjected work.

The prospective bidders, who have participated in the pre-bid, submitted following queries. Clarifications to the queries as approved by the competent authority is as under:-

1. M/s Fire Cool Engineers through its Proprietor Sh. J. S. Arneja

S.No.	Clause / Page Ref. No.	Existing Condition / Clause	Query raised by the Prospective bidder	Clarification of department
1	Sub-Head-II Item No. 5 & 6	5. Supplying, laying, testing & commissioning of 4x1.5 sqmm XLPE insulated copper conductor cable including accessories, termination glands etc. on surface with copper outer sheaths as reqd. 6. Supplying, laying, testing & commissioning of 2x1.5 sqmm XLPE insulated copper conductor cable including accessories, termination glands etc on surface with copper outer sheaths as reqd.	The cable item no. 5 & 6 do not have copper outer sheathed. It should be either armoured or unarmoured cable. It shall also be clarified whether it is FRLS or normal cable.	Revised description of items shall be read as : 5. Supplying, laying, testing & commissioning of 4x1.5 sqmm XLPE insulated copper conductor FRLS Armoured cable as per relevant IS including accessories, termination glands etc on surface as reqd. 6. Supplying, laying, testing & commissioning of 2x1.5 sqmm XLPE insulated copper conductor FRLS Armoured cable as per relevant IS including accessories, termination glands etc on surface as reqd.

2. M/s Fire Guard Engineer through its Partner Sh. Kawal Saini

S.No.	Clause / Page Ref. No.	Existing Condition / Clause	Query raised by the Prospective bidder	Clarification of department
1	Sub-Head-I Item no.	---	As per Item no. 7,8,9 & 15 is required inbuilt fault isolator with every device	It is clarified that EN compliant devices shall have in-built fault isolator. In case

(Signature)

(Signature)

	7,8,9 & 15		but as per UL norms it is required onluy after 20 to 24 devices so kindly considered fault isolator as per UL norms and amend in the BOQ.	of UL compliant devices, external fault isolator shall be used as per UL norms however nothing extra shall be paid. Rates shall be quoted accordingly.
--	---------------	--	---	--

3. M/s Pranav Sales & Projects (I) Pvt Ltd through its Director Sh. Amit Bajaj
No queries raised.
4. M/s Sarthak Fire Safety Systems through its Proprietor Sh. Deepak
No queries raised.

All prospective bidders are requested to kindly take note of above clarifications and quote the rates accordingly.

SE(E) *Maan*
24/8/17
Supervising Engineer (Elect)
(North Delhi Municipal Corporation)

[Signature]
24/8/17
Ex. Engineer (Elect.)-II

Addl. Dir. (IT)

[Signature]
24/8/17

[Signature]



NORTH DELHI MUNICIPAL CORPORATION
(ENGINEERING DEPARTMENT)

Office of Ex. Engineer (Elect.)-II, Civil Line Zone
M.C. Primary School, Hakikat Nagar, Delhi-09

No. E E (E)-II/NDMC/17-18/ 389

Date: 24/08/2017

Corrigendum

Name of Work: Construction of 200 Bedded Hospital At Balakram Hospital At Timarpur In C-10/CLZ, Delhi
Sub-Head: Providing of Addressable Fire Alarm System and Public Address System.
NIT No. EEE-II/TC/2017-18/12 Item No. 3 vide online tender No. 288211 dated 26.07.2017

The prospective bidders should take note of the following corrigendum to the tender document while preparing and submitting their bids.

S. No.	Existing Dates in NIT	Re-scheduled dates for NIT
1	Last date for downloading/purchase of bid document 18-08-2017 till 12:30PM	Last date for downloading/purchase of bid document 18-08-2017 till 12:30PM (No change)
3.	Last Date of Bid preparation & hash submission 25.08.2017 till 12:30PM.	Last Date of Bid preparation & hash submission 01.09.2017 till 12:30PM.
4.	Technical & Financial Closing of Bid: 25-08-2017 at 12:31PM to 25-08-2017 upto 15:00 PM	Technical & Financial Closing of Bid: 01-09-2017 at 12:31PM to 01-09-2017 upto 15:00 PM
5.	Date of Re-Encryption of Online Bid 25-08-2017 on 15:01PM to 28-08-2017 till 11:00AM	Date of Re-Encryption of Online Bid 01-09-2017 on 15:01PM to 05-01-2017 till 11:00AM
6	Opening of Technical bid 28-08-2017 at 11:15 AM to 28-08-2017 upto 17:00 PM	Opening of Technical bid 05-01-2017 at 11:15 AM to 05-01-2017 upto 17:00 PM
7.	Evaluation of Technical Bid From 28-08-2017 on 17:01 PM to 04-09-2017 till 11:00 PM	Evaluation of Technical Bid From 05-01-2017 on 17:01 PM to 14-09-2017 till 11:00 PM
8.	Opening of Financial bid 04-09-2017 at 11:15 AM (Tentative) or as intimated to Technically qualified bidders only	Opening of Financial bid 14-09-2017 at 11:15 AM (Tentative) or as intimated to Technically qualified bidders only

The prospective bidders are also advised to visit the website www.mcdonline.gov.in for further information on the above mentioned tender.

S E (E)-I
Addl. Dir. (IT)

Sheep
24/8/17
Superintending Engineer (Elect)
(North Delhi Municipal Corporation)

Robert
24/8/17
Superintending Engineer (Elect)
(North Delhi Municipal Corporation)

Asst

EEE-II
24/08/17