

**SOUTH DELHI MUNICIPAL CORPORATION**

**Office of the Executive Engineer(E), South Zone**

**M C Primary School, Police Colony**

**Hauz Khas, New Delhi - 110016**

No. E/E/IV/S2/2018/19/737

Dated: 15-02-19

Subject: Corrigendum regarding pre-bid meeting to NIT No- 37 dated  
8.1.19.

With reference to the above mentioned NIT, following  
amendments are hereby issued:

Amendment No 1 :

The minutes of the pre-bid meeting held in the office of SE(Elect)-II,  
SDMC on 22.1.19 as approved by the Competent Authority are as follows:

S No	Query/clarification	Firm which raised the query	Reply of the dept
1	We recommend to mention in the tender for clear opening of 1200 mm.	M/s Kone Elevator India Private Ltd	No change. Clear opening should be as per clause 12(b) of the special conditions of the NIT.
2	We recommend to mention car panel finish as stainless steel moon rock finish or stainless steel hairline finish and car ceiling finish as stainless steel hairline finish.	M/s Kone Elevator India Private Ltd	Car panel finish should be stainless steel moon rock finish / stainless steel hairline finish and car ceiling finish should be stainless steel hairline finish.
3	We recommend to incorporate LED lights for car illumination.	M/s Kone Elevator India Private Ltd	LED lights should be provided by the contractor for car illumination.
4	We recommend to incorporate 2 no of car operating panel in car as the lift is of higher capacity.	M/s Kone Elevator India Private Ltd	Two no of car operating panel in the car should be provided by lift contractor.

5	We recommend to incorporate 3 side handrails in car for convenience of senior citizen	M/s Kone Elevator India Private Ltd	Three side handrails in car should be provided by lift contractor.
6	We recommend to incorporate braille buttons for car and landing both	M/s Kone Elevator India Private Ltd	Braille buttons for both car and landing should be provided by lift contractor.
7	We will provide 3 mm thick PVC flooring.	M/s Kone Elevator India Private Ltd	3 mm thick PVC flooring should be provided by lift contractor.
8	As site, shaft is not in plumb we required. Customer has to provide plumb shaft as per our GAD.	M/s Kone Elevator India Private Ltd	Shaft shall be made in plumb by SDMC.
9	In the NIT, earnest money deposit is written as Rs 51,500/- whereas in the tender documents (special conditions), earnest money deposit is written as Rs 49,000/-. Please clarify?	M/s Kone Elevator India Private Ltd	There is a typographical error in the special conditions. Earnest money deposit is Rs 51,500/-.

The above mentioned minutes shall form part of the NIT and are to be read by the intending tenderers with the existing conditions of the NIT

Amendment No 2 :

The tender schedule for above NIT is extended as follows:

Tender stage	Extended time schedule
Period of submission of Tender	Upto 22.2.19 03:00 PM
Opening of technical bid	On 22.2.19 at 03:30 PM
Opening of financial bid	On 1.3.19 at 03:00 PM

Rest of the conditions of the tender shall remain same.

Distribution:

1. All concerned.

✓ 2. AO(TT)/SDMC – Along with request to upload this corrigendum on the website mcdonline.gov.in

*Jay*  
**EE(Elect), South Zone**  
 E.E. (Elect.)-IWSZ  
 S.D.M.C

*Jayson*  
*P. M.*